


If used in accordance with their approval the following anchors in the sizes and versions shown below comply with the requirements of



**Guidelines for sprinkler systems VdS CEA 4001: 2014 -04 (05), for fastening pipes for extinguishing systems to concrete ceilings.**

**Sikla Nail Anchor AN**, steel galvanised M8 - M16  
**Sikla Drop-In Anchor AN ES**, steel galvanised M8 - M16  
**Sikla Nail Anchor AN**, stainless steel A4 M8 - M16

Approval ETA-10/0258



**Sikla Bolt Anchor AN BZ plus**, steel galvanised M8 - M16  
**Sikla Bolt Anchor AN BZ plus**, stainless steel A4 M8 - M16

Approval ETA-10/0259



**Sikla Nail Anchor AN N6**, steel galvanised M8/M10

Zulassung ETA-13/0048



Sikla Holding Ges.m.b.H.



Dieter Klauß  
Managing director

VS-Schwenningen, 22.06.2017